


# SL45

TYPE OF TEST	RESULTS
 <p>Acoustical Performance <sup>①</sup></p>	STC 30 (Rw 31) and OITC 27 achieved with STC 32 glass (1/4" [6 mm])
	STC (Rw) 35 and OITC 30 achieved with STC 37 glass (5/16" [8 mm] laminated)
	STC (Rw) 36 and OITC 32 achieved with STC 39 glass (1/2" [12 mm] laminated)

① Excerpts of results of a three panel unit 9' 10" W x 8' 2" H (3000 mm x 2500 mm) tested in August 2019 by SG Bauakustik, Muelheim an der Ruhr, Germany, an EN DIN ISO accredited and certified independent testing laboratory.

**Check [www.NanaWall.com](http://www.NanaWall.com) for the latest updates.**

## Acoustical Performance Interpolation with Other Glazing Options

TYPE OF GLASS	GLASS ONLY STC	FLUSH SILL	
		COMPLETE SYSTEM STC (Rw)	MAXIMUM UNIT HEIGHT POSSIBLE
1/4" (6 mm) tempered	31	30	9' 6" (2900 mm)
1/4" (6 mm) laminated	35	33	9' 6" (2900 mm)
1/4" (6 mm) enhanced laminated	36	34	9' 6" (2900 mm)
5/16" (8 mm) enhanced laminated	37	35	9' 6" (2900 mm)

Contact NanaWall for other glass types