

SECTION 08 43 33 FOLDING GLASS STOREFRONTS

SECTION 08 35 13 FOLDING GLASS DOORS

NOTE: Modify footers to align when using this section name and number.

PART 1 GENERAL

1.01 SUMMARY

- A. Section includes furnishing and installing a top hung or floor track supported, sliding-folding, thermally broken, aluminum-framed glass panel system that includes:
 - 1. Aluminum frame
 - 2. Threshold
 - 3. Panels
 - 4. Sliding-folding and locking hardware
 - 5. Weather stripping
 - 6. Glass and glazing
 - 7. Insect screen (optional)
 - 8. Accessories as required for a complete working installation
- B. Related Documents and Sections: Contractor to examine Contract Documents for requirements that directly affect or are affected by Work of this Section. A list of those Documents and Sections include, but is not limited to, the following:
 - 1. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 General Requirements, Specification Sections, apply to this Section
 - 2. Section 06 10 00, Rough Carpentry: Wood framing R.O. and blocking
 - 3. Section 06 20 00, Finish Carpentry
 - 4. Section 07 27 00, Air Barriers: Building paper and building wrap
 - 5. Section 07 62 00, Sheet Metal Flashing and Trim: Flashing gutters, and other sheet metal work
 - 6. Section 07 90 00, Joint Protection
 - 7. Section 08 42 23, Glass Entrance Swing Doors
 - 8. Section 08 51 13, Aluminum Windows: NanaWall SL68, tilt-turn, casement window
 - 9. Section 09 22 16, Non-Structural Metal Framing: Metal framing R.O. and reinforcement
 - 10. Section 10 22 39, Folding Glass Partitions: NanaWall SL60

1.02 REFERENCES

- A. Reference Standards in accordance with Division 01 and current editions from the following:
 - 1. AAMA. American Architectural Manufacturers Association; www.aamanet.org

- a. AAMA 502, Voluntary Specification for Field Testing of Newly Installed Fenestration Products
 - b. AAMA 611, Voluntary Specification for Anodized Architectural Aluminum
 - c. AAMA 920, Operation / Cycling Performance
 - d. AAMA 1304, Voluntary Specification for Forced Entry Resistance of Side-Hinged Door Systems
 - e. AAMA 2604, Voluntary Specifications, Performance Requirements and Test Procedures for High Performance Organic Coatings on Aluminum Extrusions and Panels
 - f. AAMA/WDMA/CSA 101/I.S.2/A440, NAFS, North American Fenestration Standard - Specification for Windows, Doors and Skylights
2. ANSI. American National Standards Institute; www.ansi.org
 - a. ANSI Z97.1, Safety Performance Specifications and Methods of Test for Safety Glazing Material Used in Buildings
3. ASTM. ASTM International; www.astm.org
 - a. ASTM C1036, Standard Specification for Flat Glass
 - b. ASTM C1048, Standard Specification for Heat-Strengthened and Fully Tempered Flat Glass
 - c. ASTM E283, Test Method for Rate of Air Leakage through Exterior Windows, Curtain Walls, and Doors by Uniform Static Air Pressure Difference
 - d. ASTM E330, Test Method for Structural Performance of Exterior Windows, Curtain Walls, and Doors by Uniform Static Air Pressure Difference
 - e. ASTM E331, Standard Test Method for Water Penetration of Exterior Windows, Skylights, Doors, and Curtain Walls by Uniform Static Air Pressure Difference
 - f. ASTM E413, Classification for Rating Sound Insulation
 - g. ASTM E547, Test Method for Water Penetration of Exterior Windows, Curtain Walls, and Doors by Cyclic Static Air Pressure Differential
 - h. ASTM E1332, Standard Classification for Rating Outdoor-Indoor Sound Attenuation
 4. BSI Group. The British Standards Institution; <http://www.bsigroup.com/en-GB/>
 - a. PAS 24 (Publicly Available Specification), Enhanced security performance requirements for door assemblies
 5. CPSC. Consumer Product Safety Commission; www.cpsc.gov
 - a. CPSC 16CFR-1201, Safety Standard for Architectural Glazing Materials
 6. CSA Group (Canadian Standards Association); www.csagroup.org/global/en/home
 - a. CSA A440S1 - The Canadian supplement to North American (NAFS) standards
 7. DIN. "Deutsches Institut für Normung" (German institute for standardization); www.en-standard.eu/din-standards | CSN EN Standards - Construction Materials and Building (European Standards); www.en-standard.eu/din-standards
 - a. DIN EN 1191, Windows and doors - Resistance to repeated opening and closing - Test method; German version EN 1191:2000
 - b. DIN EN 1627, Pedestrian door sets, windows, curtain walling, grilles and shutters - Burglar resistance - Requirements and classification
 - c. DIN EN 1630, Pedestrian door sets, windows, curtain walling, grilles and shutters - Burglar resistance - Test method for the determination of resistance to manual burglary attempts
 - d. DIN EN ISO 9001: 2015 quality management system registration

- e. DIN EN ISO 12400, Windows and pedestrian doors - Mechanical durability - Requirements and classification
- f. DIN EN ISO 14001: 2015 environmental management system registration
- g. DIN 52210-3, Testing of acoustics in building – Airborne and impact sound insulation – Laboratory measurements of sound insulation of building elements and field measurements between rooms
- h. DIN 52210-4, Tests in Building Acoustics – Airborne and Impact Sound
- 8. Energy Star, U.S. Environmental Protection Agency (EPA) Program; www.energystar.gov
- 9. FL. Florida Building Commission - Product Approval; https://floridabuilding.org/pr/pr_app_srch.aspx
- 10. NFRC. National Fenestration Rating Council; www.nfrc.org
 - a. NFRC 100, Procedure for Determining Fenestration Product U-factors
 - b. NFRC 200, Procedure for Determining Fenestration Product Solar Heat Gain Coefficient and Visible Transmittance at Normal Incidence
 - c. NFRC 400, Procedure for Determining Fenestration Product Air Leakage
 - d. NFRC 500, Procedure for Determining Fenestration Product Condensation Resistance Rating Values

1.03 ADMINISTRATIVE REQUIREMENTS BY CONTRACTOR

- A. Coordination: Coordinate Folding Glass Storefront system and framing R.O.
- B. Preinstallation Meetings: See Section 01 30 00.

1.04 SUBMITTALS

- A. For Contractor submittal procedures see Section 01 30 00.
- B. Product Data: Submit manufacturer's printed product literature for each Folding Glass Storefront system to be incorporated into the Work. Show performance test results and details of construction relative to materials, dimensions of individual components, profiles and colors.
- C. Product Drawings: Indicate Folding Glass Storefront system component sizes, dimensions and framing R.O., configuration, swing panels, direction of swing, stacking layout, typical head jamb, side jambs and sill details, type of glazing material, handle height and field measurements.
- D. Installation, Operation and Maintenance Data: Submit Owner's Manual from manufacturer. Identify with project name, location and completion date, and type and size of unit installed.

NOTE: Delete the following Article if LEED is not applicable; edit to meet project LEED requirements.

- E. Sustainable Design Submittals (USGBC [LEED®](https://www.usgbc.org/)): Refer to Section 01 81 15, LEED Design Requirements.
 - 1. **LEED 2009** (v3) Credits. Complete online LEED forms and submit other required materials as follows:
 - a. Energy and Atmosphere (EA) Credits:
 - 1). EA Credit 1 (EA c1): Optimize Energy Performance: System
 - b. Materials and Resources (MR) Credits:
 - 1). MR Credit 1.1 (MRc1.1): Building Reuse - Maintain Existing Exterior Walls, Floors and Roof
 - 2). MR Credit 1.2 (MRc1.2): Building Reuse - Maintain Existing Interior Nonstructural Elements
 - 3). MR Credit 2 (MRc2): Construction Waste Management

NOTE: MR Credit 3 below can apply to reusing salvaged Folding Glass Storefront.

- 4). MR Credit 3: Materials Reuse - 5% (MRc3.1) or 10% (MRc3.2)

NOTE: MR Credit 5 below can apply to projects within 500 miles (805 km) of the NanaWall fabrication shop located in **Richmond, CA 94801**.

- 5). MR Credit 5: Regional Materials: 10% (MRc5.1) or 20% (MRc5.2) Extracted, Processed & Manufactured Regionally
- c. Indoor Environmental Quality (EQ) Credits:
 - 1). IEQ Credit 2 (IEQc2): Increased Ventilation - Case 2 - Naturally Ventilated Spaces
 - 2). IEQ Credit 8.1 (IEQc8.1): Daylight & Views - Daylight 75% of Spaces
 - 3). IEQ Credit 8.2 (IEQc8.2): Daylight & Views - Views for 90% of Spaces
 - 4). IEQ Credit 9 (LEED for Schools - IEQc9): Enhanced Acoustical Performance
2. **LEED v4 for Building Design and Construction (BD&C) Credits.** Complete online LEED forms and submit other required materials as follows:
 - a. Energy and Atmosphere (EA) Credits:
 - 1). EA Credit 2 (EAc2): Optimize Energy Performance
 - b. Materials and Resources (MR) Credits:

NOTE: MR Credit 1 below can apply to reusing salvaged Folding Glass Storefront.

- 1). MR Credit 1 (MRc1): Building Life-Cycle Impact Reduction; Option 3 - Building and Material Reuse
- c. Indoor Environmental Quality (EQ) Credits:
 - 1). EQ Credit 7 (EQc7): Daylight
 - 2). EQ Credit 8 (EQc8): Quality Views
 - 3). EQ Credit 9 (EQc9): Acoustic Performance
 - a). Submit calculations or measurements for occupant spaces to meet sound transmission class ratings between adjacent spaces and reverberation time requirements within a room.

F. LEED Closeout Documentation:

NOTE: Edit below to meet project LEED requirements.

1. **LEED 2009 (v3).** Submit completed LEED™ submittal Worksheet Templates for the following credits:
 - a. EAc1, MRc1.1, MRc1.2, MRc2, MRc3, MRc5, MRc6, IEQc2, IEQc8.1, IEQc8.2, IEQc9
2. **LEED v4 (BD&C).** Submit information and documentation to complete LEED™ Worksheet Templates for the following credits:
 - a. EAc2, MRc1, EQc7, EQc8, EQc9

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Manufacturer capable of providing complete, precision built, engineered, pre-fitted units with a minimum thirty (30) years' experience in the sale of folding-sliding door systems for large openings in the North American market.
 1. Manufacturer to have ISO 9001: 2015 quality management system registration.
 2. Manufacturer to have ISO 14001: 2015 environmental management system registration.
- B. Installer Qualifications: Installer experienced in the installation of manufacturer's products or other similar products for large openings. Installer to provide reference list of at least three (3) projects of similar scale and complexity successfully completed in the last three (3) years.

1. Installer to be trained and certified by manufacturer.
 - C. Single Source Responsibility: Furnish Folding Glass Storefront system materials from one manufacturer for entire Project.
- 1.06 DELIVERY, STORAGE, AND HANDLING
- A. Comply with manufacturer's instructions and recommendations, Section 01 60 00 requirements, and as follows:
 1. Deliver materials to job site in sealed, unopened cartons or crates.
 - a. Upon receipt, contractor to inspect the shipment to ensure it is complete, in good condition and meets project requirements.
 2. Contractor to store material under cover in a clean and dry location, protecting units against weather and defacement or damage from construction activities, especially to the edges of panels.
- 1.07 FIELD CONDITIONS BY CONTRACTOR
- A. Field Measurements: Contractor to field verify dimensions of rough openings (R.O.) [**and threshold depressions to receive sill.**] Mark field measurements on product drawing submittal.
- 1.08 WARRANTY
- A. Manufacturer Warranty: Provide Folding Glass Storefront system manufacturer's standard limited warranty as per manufacturer's published warranty document in force at time of purchase, subject to change, against defects in materials and workmanship.
 1. Warranty Period beginning with the earliest of 120 days from Date of Delivery or Date of Substantial Completion:
 - a. Rollers and Insulated Glass Seal Failure: Ten (10) years
 - b. All Other Components Except Screens: Ten (10) years
 - 1). Exception: Five (5) years if NOT installed by manufacturer's specific system approved or certified trained installer.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Basis-of-Design Product by Manufacturer: **NanaWall SL60** by **NANA WALL SYSTEMS, INC.** (www.nanawall.com)

NANA WALL SYSTEMS, INC.

100 Meadow Creek Drive, Corte Madera, CA 94925

Toll Free (800) 873-5673

Telephone: (415) 383-3148

Fax: (415) 383-0312

Email: info@nanawall.com

1. Substitution Procedures: See Section 01 20 00; Submit completed and signed:
 - a. Document 00 43 25, Substitution Request Form (During Procurement), or
 - b. Document 00 63 25, Substitution Request Form (During Construction)

2.02 PERFORMANCE / DESIGN CRITERIA

NOTE: Select one of the six Performance Criteria Sill type paragraphs below for Air Infiltration, Water Penetration and Structural Loading, deleting items not chosen.

Weeps, when provided, are to be drilled in the field by the installer to manufacturer's requirements.

Air infiltration and water penetration testing results are only applicable if the unit matches the tested panel and unit size, configuration, direction of opening and type of sill.

Structural load testing results are only applicable for the test unit size and type of locking and rods.

Comparative analysis charts published by manufacturer shows which panel sizes, if any, meets the structural loading design pressures specifically required for the project. Check for limitations on the use of these charts in the jurisdiction of the project.

Forced entry testing results are only applicable for the test unit type of locking.

Check for requirements in the jurisdiction of the project.

See manufacturer's latest published data regarding performance.

It is expected that the installed system's performance would be not more than 2/3rds of the following certified laboratory test data in accordance with AAMA 502.

- A. Performance Criteria (Lab Tested): **Higher Weather Performance Raised Sill - Inward Opening**
1. Air Infiltration (ASTM E283):
 - a. 0.02 cfm/ft² (0.10 L/s/m²) (0.25 (m³/h)/m) at a static air pressure difference: of 1.57 psf (75 Pa)
 - b. 0.06 cfm/ft² (0.31 L/s/m²) at 6.24 psf (300 Pa)
 2. Water Penetration (ASTM E331, ASTM E547): No uncontrolled water entry at 7.5 psf (360 Pa). (Not applicable for even-even configurations)
 3. Structural Loading (ASTM E330): [DP-40] [DP-45]
 - a. Design Pressure - Positive: 45 psf (2160 Pa)
 - b. Design Pressure - Negative: 45 psf (2160 Pa)
- B. Performance Criteria (Lab Tested): **Higher Weather Performance Raised Sill - Outward Opening**
1. Air Infiltration (ASTM E283):
 - a. 0.01 cfm/ft² (0.05 L/s/m²) at a static air pressure difference: of 1.57 psf (75 Pa)
 - b. 0.01 cfm/ft² (0.05 L/s/m²) at 6.24 psf (300 Pa)
 2. Water Penetration (ASTM E331, ASTM E547): No uncontrolled water leakage at 7.5 psf (360 Pa). (Not applicable for even-even configurations)
 3. Structural Loading (ASTM E330): [DP-40] [DP-45]
 - a. Design Pressure - Positive: 45 psf (2160 Pa)
 - b. Design Pressure - Negative: 40 psf (1920 Pa)
- C. Performance Criteria (Lab Tested): **Hybrid Sill - Inward Opening**
1. Air Infiltration (ASTM E283):
 - a. 0.05 cfm/ft² (0.09 L/s/m²) at a static air pressure difference: of 1.57 psf (75 Pa)
 - b. 0.13 cfm/ft² (0.67 L/s/m²) at 6.24 psf (300 Pa)
 2. Water Penetration (ASTM E331, ASTM E547): No uncontrolled water leakage at 7.5 psf (360 Pa). (Not applicable for even-even configurations)

3. Structural Loading (ASTM E330): [DP-40] [DP-45]
 - a. Design Pressure - Positive: 45 psf (2160 Pa)
 - b. Design Pressure - Negative: 45 psf (2160 Pa)
- D. Performance Criteria (Lab Tested): **Hybrid Sill - Outward Opening**
 1. Air Infiltration (ASTM E283):
 - a. 0.02 cfm/ft² (0.07 L/s/m²) at a static air pressure difference: of 1.57 psf (75 Pa)
 - b. 0.10 cfm/ft² (0.51 L/s/m²) at 6.24 psf (300 Pa)
 2. Water Penetration (ASTM E331, ASTM E547): No uncontrolled water leakage at 7.5 psf (360 Pa). (Not applicable for even-even configurations)
 3. Structural Loading (ASTM E330): [DP-40] [DP-45]
 - a. Design Pressure - Positive: 45 psf (2160 Pa)
 - b. Design Pressure - Negative: 45 psf (2160 Pa)
- E. Performance Criteria (Lab Tested): **Low Profile Saddle Sill - Inward/Outward Opening**
 1. Air Infiltration| Exfiltration (ASTM E283):
 - a. 0.10| 0.08 cfm/ft² (0.5| 0.4 L/s/m²) at a static air pressure difference: of 1.57 psf (75 Pa)
 - b. 0.37| 0.17 cfm/ft² (1.9| 0.9 L/s/m²) at 6.24 psf (300 Pa)
 2. Water Penetration (ASTM E331, ASTM E547): No uncontrolled water leakage at a static test pressure of 5.43 psf (260 Pa) with weeps by others.
 3. Structural Loading (ASTM E330): [DP-40] [DP-45]
 - a. Design Pressure – Positive Inswing or Negative Outswing: 40 psf (1920 Pa)
 - b. Design Pressure – Negative Inswing or Positive Outswing: 45 psf (2160 Pa)
 4. Swing Panel with Surface Mounted Hinges - Operation / Cycling Performance (AAMA 920):
500,000 cycles
- F. Performance Criteria (Lab Tested): **Standard Flush Sill - Inward/Outward Opening**
 1. Air Infiltration| Exfiltration (ASTM E283):
 - a. 0.10| 0.08 cfm/ft² (0.5| 0.4 L/s/m²) at a static air pressure difference: of 1.57 psf (75 Pa)
 - b. 0.37| 0.17 cfm/ft² (1.9| 0.9 L/s/m²) at 6.24 psf (300 Pa)
 2. Structural Loading (ASTM E330): [DP-40] [DP-45]
 - a. Design Pressure – Positive Inswing or Negative Outswing: 40 psf (1920 Pa)
 - b. Design Pressure – Negative Inswing or Positive Outswing: 45 psf (2160 Pa)
 3. Swing Panel with Surface Mounted Hinges - Operation / Cycling Performance (AAMA 920):
500,000 cycles

NOTE: Items below are common to all sill types.

4. Folding Glass Storefront Units tested to AAMA/WDMA/CSA 101/I.S.2/A440.

NOTE: For storefront units requiring acoustic performance keep the following. Edit to suit project conditions.

5. Glass Acoustical Performance (DIN 52210-3,4): With 38 Db glass, unit Rw (STC) of 36
6. System - Life Cycle Performance (DIN EN 1191/12400): Pass; 20,000 cycles
7. Forced Entry (AAMA 1304): Meets requirements

NOTE: Retain Burglary Resistance subparagraphs below when desired; these two additional security options are available for an upcharge.

8. Unit Burglary Resistance: EN 1627-30, Class RC2/ RC2N
(Resistance Class 2) certified
9. Lockset Burglary Resistance: PAS 24 certified

NOTE: Retain Florida Product Approval subparagraph below when needed to meet wind loading requirements.

10. Florida Product Approval - Wind Loading: F24434; Approved for use outside hurricane zones (HVHZ) with a Design Pressure of +45/-45 psf.

NOTE: SL60 Inswing and outswing systems are approved by the State of Florida.
https://www.floridabuilding.org/pr/pr_app_dtl.aspx?param=wGEVXQwtDqujtLuE1oYFLK%2fx8iUBOHXkse6O%2fxW0IRhMjS2CmxRSyA%3d%3d

11. Thermal Performance (U-factor): NFRC 100 rated, certified, and labeled
12. Solar Heat Gain Coefficient (SHGC) + Visible Light Transmission (VT): NFRC 200 rated, certified, and labeled
13. Air Leakage: NFRC 400 rated, certified, and labeled
14. Condensation Resistance Factor (CRF): NFRC 500 rated, certified, and labeled

NOTE: The NFRC 100, 200, 400 and 500 ratings of the SL60 Folding Glass Storefront System with specific glass meet **Prescriptive Method** requirements for U-factor, SHGC, Air Leakage and CRF of *California Title 24, Chapter 3, Building Envelope Requirements*.

For the listing of Nana Wall product NFRC testing reports go to the following website <http://search.nfrc.org/search/searchdefault.aspx>; click on **Door** (Find Ratings for Door Products); click on the **Search by Manufacturer** button; click **Manufacturers**, scroll down to and click on **Nana Wall Systems, Inc.**, and click on the **Find Products** button.

15. EPA Energy Star: Meets requirements

NOTE: **Energy Star** values for DOORS with > 50% glass can be achieved through the use of specific glass units meeting the following requirements:

Northern & North-Central Region: ≤ 0.30 U-factor 0.40 SHGC

South-Central & Southern Region: ≤ 0.30 U-factor 0.25 SHGC

Energy Star Air Leakage Rating Requirements (ASTM E283 in accordance with NFRC 400 or AAMA/WDMA/CSA 101/I.S.2/A440-11):

Swinging Door: ≤ 0.5 cfm/ft² (2.56 L/s/m²)

For guidance only as Nana Wall Systems is not a participant of the Energy Star Program.

G. LEED Characteristics:

1. **LEED 2009** (v3)

- EAc1: *NanaWall* systems using low U-Value designed double or triple IGU and thermally broken frames can provide significant energy performance.
- MRc1.1: *NanaWall* exterior glass wall systems, not demolished in a renovation project, are reused in the same location.
- MRc1.2: *NanaWall* interior glass wall systems, not demolished in a renovation project, are reused in the same location.
- MRc2: *NanaWall* cardboard shipping crates are made of 60% recycled material and are 100% recyclable.
- MRc3: *NanaWall's* components easily disassemble and reassemble to "Use as salvaged... or reused materials."
- MRc5: *NanaWall* glazing, panel, track and door manufacturing final assembly plant is located in Richmond, CA 94801.

- g. IEQc2: *NanaWall* systems provide natural ventilation in the open position, assisting in the 90% required natural ventilation of occupied spaces of ASHRAE 62.1.
 - h. EQc8.1: *NanaWall* glass wall assembly borrowed light brings daylight deeper into the floor plate.
 - i. EQc8.2: *NanaWall* glass wall assemblies provide direct outdoor lines of sight.
2. **LEED v4 for Building Design and Construction (BD&C)**
- a. EAc2: *NanaWall* systems using low U-Value designed double or triple IGU and thermally broken frames can provide significant energy performance.
 - b. MRc1: *NanaWall* can be easily disassembled for salvage and reuse.
 - c. EQc7: *NanaWall* glass wall assembly borrowed light brings daylight deeper into the floor plate.
 - d. EQc8: *NanaWall* glass wall assemblies provide direct outdoor lines of sight.
- H. Design Criteria:
1. Sizes and Configurations: As indicated by the Drawings for selected number and size of panels, location of swing panels, and stacking.
 2. Unit Operation: Sliding and folding hardware with top and bottom tracks.
 3. Mounting Type:
 - a. [Top-hung]
 - b. [Floor track supported]
 4. Panel Configuration:
 - a. [Straight]
 - b. [Window/door combination]
 5. Panel Type: Hinged
 - a. Primary swing panel of paired swing panels, looking from inside, to be on the [**left**] [**right**].
 - b. [Entry/Egress panel hinged to side jamb.]
 6. Panel Pairing Configuration: See Drawings.
- NOTE:** Sizes and Configurations: <http://www.nanawall.com/products/sl60/options>
 See manufacturer drawings for selected custom dimensions within maximum frame sizes possible as indicated in manufacturer's literature.
 See drawings for selected number of panels and configuration.
7. Stack Storage Configuration:
 - a. [Inswing]
 - b. [Outswing]

2.03 MATERIALS

- A. Thermally Broken Aluminum Framed Folding Glass Storefront Description: Top-hung or floor track supported system. Manufacturer's standard frame and panel profiles, with head track, side jambs and panels with dimensions as shown on Drawings.
1. Panels and Frames
 - a. Panels
 - 1). Single lite.

NOTE: Single lite above is standard; other options below may require an upcharge.
Refer to manufacturer's size chart for glass panel sizes requiring the use of horizontal mullions.

- 2). [Multiple lites with horizontal mullion(s) at height(s) indicated from the bottom of the panel.]
- 3). [Single lite with simulated divided lites in pattern as shown on Drawings.]
- 4). Panel Size (W x H): As indicated.

NOTE: Maximum panel sizes of 3'-3" x 8'-6" (1.0 x 2.6 m) to 2'-11" x 9'-6" (0.9 x 2.9 m).

- 5). Rail Depth: 2-5/16 inch (59 mm)
- 6). Top Rail and Stile Width: 2-3/8 inch (60 mm)
- 7). Bottom Rail Width: 2-3/8 inch (60 mm)

NOTE: Indicate kickplate height. Select height between 6 and 12 inches (152 and 305 mm) high.

- a). [Manufacturer's standard kickplate with height indicated.]
- b. Frame:
 - 1). Matching top track and side jambs
 - a). Top Track Width (Top-Hung): 3-15/16 inch (100 mm)
 - b). Top Track Width (Floor Supported): 2-9/16 inch (65 mm)
 - c). Side Jambs Width: 2-9/16 inch (65 mm)
 - d). Top Track and Side Jambs Depth: 3-1/8 inch (66 mm)

NOTE: Select from the following Sill types, edit to suit and delete those not meeting project requirements.

- 2). Sill Type:
 - a). [Higher weather performance raised sill (thermally broken)]
 - b). [Hybrid sill (thermally broken)]
 - c). [Low profile saddle sill (thermally broken)]
 - d). [Flush sill (thermally broken)]
 - e). [Surface mounted interior sill (not thermally broken) only for floor supported system in interior application]
 - 3). Sill Aluminum Finish:
 - a). [a clear anodized finish.]
 - b). [a dark bronze anodized finish.]
 - c). [finished to match panel only with higher weather performance sill.]
 - 4). For ADA Compliance at Swing Panel: Provide gasket to cover the channel in the sill at swing panels.
2. Aluminum Extrusion: AIMgSi0.5 alloy, 6063-T5 (F-22 - European standard)
 - a. Thickness: 0.078 inch (2.0 mm) nominal
 - b. Thermal Break: 7/8 inch (22 mm) wide polyamide plastic reinforced with glass fibers. Narrower or poured and de-bridged type thermal breaks not acceptable.
 3. Panel and Frame Aluminum Finish: Inside and Outside;
 - a. [Same (one-color)]
 - b. [Different (two-tone)]

NOTE: Select finish type below, edit to requirements and delete items not used.

- c. Anodized (AAMA 611):
 - 1). [Clear]
 - 2). [Dark Bronze]
 - d. Powder Coat (AAMA 2604):
 - 1). Color as chosen from manufacturer's powder coating finish chart from
 - a). [Manufacturer's standard selection of 50 colors - Matte.]
 - b). [manufacturer's full RAL selection.]
 - i. [High Gloss]
 - ii. [Matte]
 - c). [custom finish.]
- B. Glass and Glazing:
- 1. Safety Glazing: In compliance with ASTM C1036, ASTM C1048, ANSI Z97.1 and CPSC 16CFR 1201.
 - 2. Manufacturer's [**tempered**] [**and**] [**laminated**] glass lites in [**double**] [**triple**] insulated glazing units, dry glazed with glass stops on the inside.

NOTE: Select and edit glass type(s) to meet building code, wind-load design, acoustic, security, and other project requirements with other glass available from manufacturer.

Contact NanaWall for availability of other commercial glass types.

- a. Insulated Glass Unit (IGU) Lites:
 - 1). Double IGU:
 - a). 15/16 inch (24 mm) thick.
 - 2). Triple IGU:
 - a). 1-3/8 inch (35 mm) thick.
- b. IGU Fill:
 - 1). Air filled
 - 2). [Argon filled]
 - 3). [Krypton filled]
- c. Glass Lite Type:
 - 1). Standard

NOTE: Items below are options and may require an upcharge.

- 2). [Low iron]
- 3). [Solar bronze]
- 4). [Solar gray]
- 5). [Bird safe]
- d. Glass Spacers: Manufacturer's standard
 - 1). [gray finish with capillary tubes]
 - 2). [dark bronze finish with capillary tubes]
 - 3). [gray finish without capillary tubes]
 - 4). [dark bronze finish without capillary tubes]

- e. IGU Surface:
 - 1). Clear
 - 2). [Low-E coating on # 2 surface of double IGU]
 - 3). [Low-E coating on # 2 and # 4 surface of double IGU]
 - 4). [Low-E coating on # 2 and # 5 surface of triple IGU]

C. Locking Hardware and Handles:

NOTE: Select one of the below Main Entry Panel paragraphs WITH or WITHOUT Swing Panels, deleting all others. Edit to suit project requirements.

1. Main Entry [**Pair of**] Panel(s) for Models WITH a [**Pair of**] Swing Panels: Provide manufacturer's [**Standard lever handles**] or [**Lever handles with return**] on the inside and outside, and a lockset with a lockable latch, and multi-point locking with a dead bolt and rods at the top and bottom on primary panel [**only**].
 - a. Rods to be concealed and not edge mounted.
 - b. After turn of key or thumb-turn, depression of handles withdraws latch.
 - c. Lifting of handles engages rods and turn of key or thumb turn engages deadbolt and operates lock.
 - d. [Secondary Swing Panel: Provide matching dummy lever handles on both sides and concealed flush bolts that operate the rods at the top and the bottom for the secondary swing panel.]

NOTE: Secondary swing panel paragraph above is standard with pairs; hardware for Secondary Panel below is an option.

- e. [Secondary Swing Panel: Provide two-point locking with flat handles on inside only for the secondary swing panel.]
- f. Lever Handle - Finish:
 - 1). Brushed satin stainless steel
 - 2). [Titanium black stainless steel]

NOTE: Handles above are standard; optional handle types below may require an upcharge. Lever handle with return are only available in "Brushed satin stainless steel." Other compatible lever, L-shaped and push-pull handle styles and finishes are available from other suppliers.

- 3). [Copper-nickel stainless steel antiviral and antimicrobial]
- 4). [Oil rubbed bronze solid brass]
- 5). [Satin nickel solid brass]
- 6). [White solid brass]
- g. Locking:
 - 1). Standard profile cylinder
 - 2). [Adapter for Small Format Interchangeable Core (SFIC) by others]
2. Main Entry [**Pair of**] Panel(s) for Models WITH a Swing Panel attached to the Side Jamb and with Surface Mounted Hinges: Provide manufacturer's push-pull handles with separate lockset and dead bolt.

NOTE: Copper-nickel finish handle may require an upcharge.

- a. Push-pull handles in a brushed stainless-steel finish and stainless-steel flat handles in a [**brushed satin finish.**] [**titanium black finish.**] [**copper-nickel finish.**]

NOTE: Door closer by others is needed to keep panels closed when deadbolt is not engaged."

3. Main Entry [**Pair of**] Panel(s) for Models WITH [**Single**] [**Paired**] Swing Panel attached to the Side Jamb and with Surface Mounted Hinges: No hardware or locking provided by manufacturer; Field installed panic device by Section 08 71 00.

NOTE: Panic device that functions with narrow stiles only.

4. Main Entry Pair of Panels on Inswing Models WITHOUT a Swing Panel: Provide manufacturer's standard L-shaped handle on the inside, flat handle on the outside and lock set with profile cylinder. Operation of lock set is by turn of key from the outside and with a thumb-turn from the inside with a two-point locking hardware operated by 180° turn of the handle.
 - a. L-Shaped Handles - Finish:
 - 1). Brushed satin stainless steel
 - 2). [Titanium black stainless steel]

NOTE: Handles above are standard, optional handle below may require an upcharge.

- 3). [Copper-nickel stainless steel antiviral and antimicrobial]
5. Main Entry [**Pair of**] Panel(s) for Outswing Models WITHOUT Swing Panel(s): Provide manufacturer's standard flat handle on the inside and a lock set with a profile cylinder on the outside. Operation of lock set is by turn of key from the outside and from the inside with a two-point locking hardware operated by 180° turn of the handle.

NOTE: Key operation from the inside may not meet egress requirements.

6. Main Entry [**Pair of**] Panel(s) for Models WITHOUT Swing Panel(s): Provide manufacturer's standard flat handle on inside only with concealed two-point locking hardware operated by 180° turn of handle.

NOTE: With this option main entry panel is operable from inside only and there is no latch.

7. Secondary Panels and Pairs of Folding Panels: Provide manufacturer's [**Flat handles**] [**Removable custodial handles**] and concealed one or two-point locking hardware operated by 180° turn of handle between each pair. Face applied flush bolt locking not acceptable (except for units with paired panels).

NOTE: Flat handles above are standard with removable custodial handles an option.

- a. Flat Handle - Finish:
 - 1). Brushed satin stainless steel
 - 2). [Titanium black stainless steel]

NOTE: Handles above are standard; optional handle types below may require an upcharge.

- 3). [Copper-nickel stainless steel antiviral and antimicrobial]
- 4). [Aluminum with powder coat color finish to match frame.]
8. Handle Height: 41-3/8 inch (105 cm) centered from bottom of panel or as otherwise indicated.
9. Aluminum locking rods with standard fiberglass reinforced polyamide end caps at the top and bottom. Rods to have a stroke of 15/16 inch (24 mm).
10. Additional profile cylinders to be [**keyed alike.**] [**keyed differently.**]
- D. Sliding- Folding Hardware: Provide manufacturer's standard combination sliding and folding hardware with top and bottom tracks and threshold. All running carriages to be with sealed, self-lubrication, ball bearing multi- rollers. Surface mounted hinges and running carriages not acceptable.

1. For Each Pair of Folding Panels:
 - a. Top-Hung System (SL60/o): Provide independent cardanic suspension for four (4) wheeled rollers coated with fiberglass reinforced polyamide upper running carriage and lower guide carriage. Running carriage to be adjustable in height, 1/4 inch (6 mm) up and down.
 - b. Floor Supported System (SL60/u): Provide upper guide carriage and lower running carriage with two vertical stainless-steel wheels and two horizontal wheels. Vertical wheels to ride on stainless steel guide track covers over the full length of sill track and lie above the water run-off level.
 - 1). Lower Running Carriage Carrying Capacity: 220 lbs. (100 kg)
2. On All Four Corners of Panels: Provide thermally broken die cast zinc multi-functional corner fittings with carriage connectors, hinges and [**standard**] [**removable**] hinge pins.

NOTE: For Easy Cleaning option of top-hung, inward-opening applications, specify "removable" hinge pins above.

- a. Finish: Powder coated, closest match to finish of frame and panel.

NOTE: Corner connectors are only available in powder coat finishes and need close attention for an aesthetic match when anodized panels and frames are specified.

3. Adjustment: Provide 1/16 inch (1.5 mm) in width per hinge adjustments without removing panels from tracks and without needing to remove panels from tracks.
- E. Weather stripping: Manufacturer's double layer EPDM between panels, EPDM gasket and Q-Ion gasket, or brush seal between panel and frame, or brush seals with a two-layer fiberglass reinforced polyamide fin attached at both inner and outer edge of bottom of door panels with a recessed sill or on frame for sealing between panels and between panel and frame.

NOTE: The manufacturer's weather stripping is determined at the factory by the direction of swing, the panel configuration, the type of locking and the type of sill.

1. UniverSILL: For outswing low profile saddle sill, UniverSILL gasket add on available for additional air and water protection.

- F. Fasteners: Tapered pins and stainless-steel screws for connecting frame components.

2.04 FABRICATION

- A. Folding Glass Wall: Extruded aluminum frame and panel profiles, corner connectors and hinges, sliding and folding hardware, locking hardware and handles, glass and glazing and weather-stripping components needed to construct a folding glass wall.

1. Each unit factory pre-assembled and shipped with complete system components and installation instructions.
2. Exposed work to be carefully matched to produce continuity of line and design with all joints.
3. No raw edges visible at joints.

2.05 ACCESSORIES

- A. **Insect Screen:** Fully retractable non-pleated screen made of ultra-strong, UV resistant fiberglass mesh housed in a single cartridge riding on a single track.

1. Basis-of-Design Product by Manufacturer: **The Horizon by Wizard Industries, Inc.**

WIZARD INDUSTRIES, INC.

4263 Phillips Ave, Burnaby, BC, Canada V5A 2X4

Toll Free: (888) 949-3667

Telephone: (604) 299-8878

Fax: (604) 299-4496

Email: sales@wizardindustries.com<https://www.wizardscreens.com/>**PART 3 EXECUTION****3.01 EXAMINATION**

- A. Examination and Acceptance of Conditions per Section 01 70 00 and as follows:
1. Carefully examine rough openings with Installer present, for compliance with requirements affecting Work performance.
 - a. Examine surfaces of openings and verify dimensions; verify rough openings are level, plumb, and square with no unevenness, bowing, or bumps on the floor; and other conditions as required by the manufacturer for readiness to receive Work.
 - b. Verify structural integrity of the header for deflection with live and dead loads limited to the lesser of L/720 of the span or 1/4 inch (6 mm). Provide structural support for lateral loads, and both wind load and eccentric load when the panels are stacked open.

NOTE: Prior to installing NanaWall, it is recommended that all building dead loads be applied to the header. Allow a reasonable amount of time for the dead load's effect on the header; only then can the building's live load be used to meet the above requirements of L/720 or 1/4 inch (6 mm). If this is not done, both dead and live loads need to be considered.

2. Proceed with installation only after unsatisfactory conditions have been corrected.

3.02 INSTALLATION

- A. General: Install Folding Glass Storefront system in accordance with the Drawings, approved submittals, manufacturer's recommendations and installation instructions, and as follows:
1. Properly flash, waterproof and seal around opening perimeter.
 2. Securely attach anchorage devices to rigidly fit frame in place, level, straight, plumb and square. Install frame in proper elevation, plane and location, and in proper alignment with other work
 3. When lower track is designed to drain, provide connections to allow for drainage.
 4. Install panels, handles, lockset, screens and other accessories in accordance with manufacturer's recommendations and instructions.

3.03 FIELD QUALITY CONTROL

- A. Field Tests and Inspections per Section 01 40 00 of the following:
1. Verify the Folding Glass Storefront system operates and functions properly. Adjust hardware for proper operation.
- B. Non-Conforming Work: Repair or replace non-conforming work as directed by the Architect; see General and Supplementary Conditions, and Division 01, General Requirements.

3.04 CLEANING AND PROTECTION

- A. Keep units closed and protect Folding Glass Storefront installation against damage from construction activities.

- B. Remove protective coatings and use manufacturer recommended methods to clean exposed surfaces.

END OF SECTION

DISCLAIMER:

Nana Wall Systems, Inc. takes no responsibility for product selection or application, including, but not limited to, compliance with building codes, safety codes, laws, or fitness for a particular purpose. This guide specification is not intended to be verbatim as a project specification without appropriate modifications for the specific use intended and the requirements of a specific construction project.

www.nanawall.com