

SECTION 08 52 00

WOOD WINDOWS

PART 1 GENERAL

1.01 SUMMARY

- A. Section includes furnishing and installing a wood framed, dual-action, tilt-turn casement window/door system that includes:
 - 1. Solid wood frame and sash
 - 2. Tilt-turn hardware
 - 3. Handles
 - 4. Weatherstripping
 - 5. Glass and glazing
 - 6. Insect screens, fixed
 - 7. Accessories as required for a complete working installation.
- B. Related Documents and Sections: Contractor to examine Contract Documents for requirements that directly affect or are affected by Work of this Section. A list of those Documents and Sections include, but is not limited to, the following:
 - 1. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 General Requirements, Specification Sections, apply to this Section.
 - 2. Section 06 10 00, Rough Carpentry: Wood framing R.O. and blocking.
 - 3. Section 06 20 00, Finish Carpentry.
 - 4. Section 07 27 00, Air Barriers: Building paper and buildingwrap
 - 5. Section 07 62 00, Sheet Metal Flashing and Trim: Flashing gutters, and other sheet metal work.
 - 6. Section 07 90 00, Joint Protection
 - 7. Section 08 43 11, Wood Framed Folding Glass Storefronts: NanaWall WD65
 - 8. Section 08 43 11, Wood Framed Folding Glass Storefronts: NanaWall WD66
 - 9. Section 08 43 31, Wood Framed Sliding Glass Storefronts: NanaWall HSW66
 - 10. Section 09 22 16, Non-Structural Metal Framing: Metal framing R.O. and reinforcement.
 - 11. Section 10 22 41, Wood Framed Folding Glass Partitions: NanaWall WD65
 - 12. Section 10 22 41, Wood Framed Folding Glass Partitions: NanaWall WD66
 - 13. Section 10 22 45, Wood Framed Sliding Glass Storefronts: NanaWall HSW66

1.02 REFERENCES

- A. Reference Standards in accordance with Division 01 and current editions from the following:
 - 1. AAMA. American Architectural Manufacturers Association; www.aamanet.org
 - a. AAMA 503, Voluntary Specification for Field Testing of Newly Installed Storefronts, Curtain Walls, and Sloped Glazing Systems
 - b. AAMA/WDMA/CSA 101/I.S.2/A440, NAFS, North American Fenestration Standard - Specification for Windows, Doors and Skylights
 - 2. ANSI. American National Standards Institute; www.ansi.org
 - a. ANSI Z97.1, Safety Performance Specifications and Methods of Test for Safety Glazing Material Used in Buildings

3. ASTM. ASTM International; www.astm.org
 - a. ASTM C1036, Standard Specification for Flat Glass
 - b. ASTM C1048, Standard Specification for Heat-Strengthened and Fully Tempered Flat Glass
 - c. ASTM E283, Test Method for Rate of Air Leakage through Exterior Windows, Curtain Walls, and Doors by Uniform Static Air Pressure Difference.
 - d. ASTM E330, Test Method for Structural Performance of Exterior Windows, Curtain Walls, and Doors by Uniform Static Air Pressure Difference.
 - e. ASTM E331, Standard Test Method for Water Penetration of Exterior Windows, Skylights, Doors, and Curtain Walls by Uniform Static Air Pressure Difference.
 - f. ASTM E413, Classification for Rating Sound Insulation
 - g. ASTM E547, Test Method for Water Penetration of Exterior Windows, Curtain Walls, and Doors by Cyclic Static Air Pressure Differential.
 - h. ASTM E1332, Standard Classification for Rating Outdoor-Indoor Sound Attenuation
 - i. ASTM F588, Standard Test Methods for Measuring the Forced Entry Resistance of Window Assemblies
4. CPSC. Consumer Product Safety Commission; www.cpsc.gov
 - a. CPSC 16CFR-1201, Safety Standard for Architectural Glazing Materials
5. CSA Group (Canadian Standards Association); www.csagroup.org/global/en/home
 - a. CSA A440S1 - The Canadian supplement to North American (NAFS) standards
6. DIN. "Deutsches Institut für Normung" (German institute for standardization); www.en-standard.eu/din-standards | EN Standards - Construction Materials and Building (European Standards); www.en-standard.eu/din-standards
 - a. DIN EN 1627, Pedestrian doorsets, windows, curtain walling, grilles and shutters - Burglar resistance - Requirements and classification
 - b. DIN EN 1630, Pedestrian doorsets, windows, curtain walling, grilles and shutters - Burglar resistance - Test method for the determination of resistance to manual burglary attempts

1.03 ADMINISTRATIVE REQUIREMENTS

- A. Coordination: Coordinate Wood Window system and framing R.O.
- B. Preinstallation Meetings: See Section 01 30 00.

1.04 SUBMITTALS

- A. For Contractor submittal procedures see Section 01 30 00.
- B. Product Data: Submit manufacturer's printed product literature for each product to be incorporated into the Work. Show performance test results and details of construction relative to materials, dimensions of individual components, profiles and colors.
- C. Product Drawings: Indicate Tilt Turn Window system component sizes, dimensions and framing R.O., configuration, direction of swing, typical head jamb, side jambs and sill details, type of glazing material, handle height and field measurements.
- D. Installation, Operation and Maintenance Data: Submit Owner's Manual from manufacturer. Identify with project name, location and completion date, and type and size of unit installed.

NOTE: Delete the following Article if LEED is not applicable; edit to meet project LEED requirements.

- E. Sustainable Design Submittals (USGBC [LEED®](https://www.usgbc.org/)): Refer to Section 01 81 15, LEED Design Requirements.

1. **LEED 2009** (v3) Credits. Complete online LEED forms and submit other required materials as follows:
 - a. Energy and Atmosphere (EA) Credits:
 - 1). EA Credit 1 (EA1): Optimize Energy Performance: System
 - b. Materials and Resources (MR) Credits:
 - 1). MR Credit 1.1 (MR1.1): Building Reuse - Maintain Existing Exterior Walls, Floors and Roof
 - 2). MR Credit 1.2 (MR1.2): Building Reuse - Maintain Existing Interior Nonstructural Elements
 - 3). MR Credit 2 (MR2): Construction Waste Management.

NOTE: MR Credit 3 below can apply to reusing salvaged Tilt Turn Wood Windows.

- 4). MR Credit 3: Materials Reuse - 5% (MR3.1) or 10% (MR3.2)
 - 5). MR Credit 7 (MR7): Certified Wood
 - a). Submit percentage of products made from plant materials with a less than 10-year harvest cycle against the total value of building materials on the project.
 - c. Indoor Environmental Quality (EQ) Credits:
 - 1). IEQ Credit 2 (IEQ2): Increased Ventilation - Case 2 - Naturally Ventilated Spaces
 - 2). IEQ Credit 8.1 (IEQ8.1): Daylight & Views - Daylight 75% of Spaces
 - 3). IEQ Credit 8.2 (IEQ8.2): Daylight & Views - Views for 90% of Spaces
 - 4). IEQ Credit 9 (LEED for Schools - IEQ9): Enhanced Acoustical Performance
2. **LEED v4 for Building Design and Construction (BD&C)** Credits. Complete online LEED forms and submit other required materials as follows:
 - a. Energy and Atmosphere (EA) Credits:
 - 1). EA Credit 2 (EA2): Optimize Energy Performance
 - b. Materials and Resources (MR) Credits:

NOTE: MR Credit 1 below can apply to reusing salvaged Tilt Turn Wood Windows.

- 1). MR Credit 1 (MR1): Building Life-Cycle Impact Reduction; Option 3 - Building and Material Reuse
 - c. Indoor Environmental Quality (EQ) Credits:
 - 1). EQ Credit 7 (EQ7): Daylight
 - 2). EQ Credit 8 (EQ8): Quality Views
 - 3). EQ Credit 9 (EQ9): Acoustic Performance
 - a). Submit calculations or measurements for occupant spaces to meet sound transmission class ratings between adjacent spaces and reverberation time requirements within a room.

F. LEED Closeout Documentation:

NOTE: Edit below to meet project LEED requirements.

1. **LEED 2009** (v3). Submit completed LEED™ submittal Worksheet Templates for the following credits:
 - a. EA1, MR1.1, MR1.2, MR2, MR3, MR7, MR6, IEQ2, IEQ8.1, IEQ8.2, IEQ9
2. **LEED v4** (BD&C). Submit information and documentation to complete LEED™ Worksheet Templates for the following credits:
 - a. EA2, MR1, EQ7, EQ8, EQ9

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Manufacturer capable of providing complete, precision built, engineered, pre-fitted units with a minimum thirty (30) years' experience in the sale of tilt turn window systems in the North American market.
 - 1. Manufacturer to have ISO 9001: 2015 quality management system registration.
 - 2. Manufacturer to have ISO 14001: 2015 environmental management system registration.
- B. Installer Qualifications: Installer experienced in the installation of manufacturer's products or other similar products. Installer to provide reference list of at least three (3) projects of similar scale and complexity successfully completed in the last three (3) years.
 - 1. Installer to be trained and certified by manufacturer.
- C. Single Source Responsibility: Furnish Wood Window system materials from one manufacturer for entire Project.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Comply with manufacturer's instructions and recommendations, Section 01 60 00 requirements, and as follows:
 - 1. Deliver materials to job site in sealed, unopened cartons or crates.
 - a. Upon receipt, inspect the shipment to ensure it is complete, in good condition and meets project requirements.
 - 2. Condition wood components to average prevailing relative humidity before installation. Do not subject wood components to extreme nor rapid changes in heat or humidity.
 - 3. Do not use forced heat to dry out building.
 - 4. Store flat in a well-ventilated area out of direct sunlight under cover in a clean and dry location, protecting units against weather and defacement or damage from construction activities, especially to the edges of panels.

1.07 FIELD CONDITIONS

- A. Field Measurements: Contractor to field verify dimensions of rough openings (R.O.) Mark field measurements on product drawing submittal.
- B. Do not use forced heat to dry out building.

1.08 WARRANTY

- A. Manufacturer Warranty: Provide Tilt Turn Wood Window system manufacturer's standard limited warranty as per manufacturer's published warranty document in force at time of purchase, subject to change, against defects in materials and workmanship.
 - 1. Warranty Period beginning with the earliest of 120 days from Date of Delivery or Date of Substantial Completion:
 - a. Rollers and Glass Seal Failure: Ten (10) years
 - b. All Other Components Except Screens: Ten (10) years
 - 1). Exception: Five (5) years if NOT installed by manufacturer's specific system approved or certified trained installer.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Basis-of-Design Product by Manufacturer: **NanaWall WD68** by **NANA WALL SYSTEMS, INC.** (www.nanawall.com)

NANA WALL SYSTEMS, INC.

100 Meadow Creek Drive, Corte Madera, CA 94925

Toll Free (800) 873-5673

Telephone: (415) 383-3148

Fax: (415) 383-0312

Email: info@nanawall.com

1. Substitution Procedures: See Section 01 20 00; Submit completed and signed:
 - a. Document 00 43 25, Substitution Request Form (During Procurement), or
 - b. Document 00 63 25, Substitution Request Form (During Construction)

2.02 PERFORMANCE / DESIGN CRITERIA

NOTE: Air infiltration and water penetration testing results are only applicable if the unit matches the tested panel and unit size, direction of opening and type of sill.

Structural load testing results are only applicable for the test unit size and type of locking and rods.

Comparative analysis charts published by manufacturer shows which panel sizes, if any, meets the structural loading design pressures specifically required for the project. Check for limitations on the use of these charts in the jurisdiction of the project.

Forced entry testing results are only applicable for the test unit type of locking.

Check for requirements in the jurisdiction of the project.

See manufacturer's latest published data regarding performance.

It is expected that the installed system's performance would be not more than 2/3rds of the following certified laboratory test data in accordance with AAMA 503.

A. Performance Criteria (Lab Tested):

1. Tilt Turn Window Units (AAMA/WDMA/CSA 101/I.S.2/A440): AAMA DAW-C70
2. Air Infiltration (ASTM E283):
 - a. 0.01 cfm/ft² (0.10 L/s/m²) at a static air pressure difference of 1.57 psf (75 Pa)
 - b. 0.01 cfm/ft² (0.10 L/s/m²) at 6.24 psf (300 Pa)
3. Water Penetration (ASTM E547 and ASTM E331):
 - a. No uncontrolled water leakage at a static test pressure of 13.5 psf (645 Pa)
4. Structural Load Deflection (ASTM E330): Pass
 - a. Design Pressure - Positive: 70 psf (3360 Pa)
 - b. Design Pressure - Negative: 120 psf (5745 Pa)
5. Forced Entry (ASTM F588): Grade 20 (AAMA CAWM 301)

NOTE: Retain Burglary Resistance subparagraph below when desired; this additional security option is available for an upcharge.

6. Unit Burglary Resistance: EN 1627-30, Class RC2/ RC2N (Resistance Class 2) certified

B. LEED Characteristics:

1. **LEED 2009** (v3)
 - a. EAc1: *NanaWall* systems using low U-Value designed double or triple IGU and thermally broken frames can provide significant energy performance.
 - b. MRc1.1: *NanaWall* exterior window systems, not demolished in a renovation project, are reused in the same location.
 - c. MRc1.2: *NanaWall* interior window systems, not demolished in a renovation project, are reused in the same location.

- d. MRc2: *NanaWall* cardboard shipping crates are made of 60% recycled material and are 100% recyclable.
- e. MRc3: *NanaWall's* components easily disassemble and reassemble to "*Use as salvaged... or reused materials.*"
- f. MRc7: *NanaWall* system wood window frames can be FSC-certified.
- g. IEQc2: *NanaWall* systems provide natural ventilation in the open position, assisting in the 90% required natural ventilation of occupied spaces of ASHRAE 62.1.
- h. EQc8.1: *NanaWall* window assembly borrowed light brings daylight deeper into the floor plate.
- i. EQc8.2: *NanaWall* window assemblies provide direct outdoor lines of sight.

2. LEED v4 for Building Design and Construction (BD&C)

- a. EAc2: *NanaWall* systems using low U-Value designed double or triple IGU and thermally/ acoustically broken frames can provide significant energy performance.
- b. MRc1: *NanaWall* can be easily disassembled for salvage and reuse.
- c. EQc7: *NanaWall* window assembly borrowed light brings daylight deeper into the floor plate.
- d. EQc8: *NanaWall* window assemblies provide direct outdoor lines of sight.

C. Design Criteria:

1. Sizes and Configurations: As indicated by the drawings for dimensions, swing and number of single tilt turns, double sash tilt turns, and double tilt turns with mullion. On double sash tilt turn, looking from inside, tilt turn panel is on the [**left**] [**right**].
2. Unit Operation: Inswing
3. Window Configuration: [**Single**] [**Paired**]

2.03 MATERIALS

A. Wood Window Description: Manufacturer's standard frame and panel profiles, with head and bottom tracks, side jambs and panels with dimensions as shown on Drawings.

1. Max. Window H x W: As indicated.

NOTE: Maximum **tilt-turn** panel size using a net glass thickness of 5/16 inch (8 mm) is 8'-2" (2.5 m) high and 4'-3" (1.3 m) wide, but not more than 24 sq. ft. (2.3 m²).
Maximum **fixed** panel size using a net glass thickness of 5/16 inch (8 mm) is 9'-2" (2.8 m) high and 6'-6" (2.0 m) wide, but not more than 24 sq. ft. (2.3 m²).

2. Wood Frame: Solid, three layers, cross-grained, kiln dried with matching solid wood glazing stops. Veneered wood Not acceptable

a. Dimensions:

- 1). Rail Depth: 2-5/8 inch (66 mm)

NOTE: Sash rail protrudes 3/4 inch (18 mm) further into the depth of the interior.

- 2). Sash Rail Width: 3-1/16 inch (78 mm)
- 3). Head & Jamb Rail Width: 4-1/2 inch (115 mm)
- 4). Sill Rail Width: 5-3/16 inch (132 mm)

- b. Double Sash Tilt Turn: Looking from inside, tilt turn panel on the [**left.**] [**right.**]

3. Sash:

- a. Single lite.

NOTE: Single lite above is standard; other options below may require an upcharge.

- b. [Horizontal mullion(s) at specified height(s) from the bottom of the panel.]

- c. [Simulated divided lites in pattern as indicated on Drawings.]
- 4. Aluminum Extrusion: AIMgSi0.5 alloy, 6063-T5 (F-22 - European standard)
 - a. Thickness: 0.078 inch (2.0 mm) nominal
 - b. Thermally broken with polyamide plastic reinforced with glass fibers and additional insulating foam.
- 5. Aluminum Finish:

NOTE: Select finish type below, edit to requirements and delete items not used.

- a. Anodized (AAMA 611): Clear
- b. Powder Coat (AAMA 2604):
 - 1). Color as chosen from manufacturer's powder coating finish chart from
 - a). [manufacturer's standard selection of 50 colors - matte.]
 - b). [manufacturer's full RAL selection.]
 - i. [High Gloss]
 - ii. [Matte]
 - c). [custom finish.]
- 6. Wood: Cross-grained, triple laminated solid wood with mortise and tenon, and glued and pinned corners. Veneered wood not acceptable.

NOTE: FSC certified wood Sapeli Mahogany is LEED credit qualified. Others available upon request.
PEFC certified wood Douglas fir does NOT qualify for LEED credit but does meet US Lacey Act requirements.

- a. Species:
 - 1). [FSC Sapeli Mahogany]
 - 2). [European Pine]
 - 3). [Spruce]
 - 4). [Western Hemlock]
 - 5). [Meranti]
 - 6). [European Oak]
 - 7). [PEFC Douglas fir]

NOTE: Beech, Maple and Cherry are for interior applications only.

- 8). [Beech]
- 9). [Maple]
- 10). [Cherry]
- b. Wood Finish: Provide factory water-based, open pore [**clear sanding sealer for stain**] [**base coat applied for paint**]; See Section 09 90 00 for field finish.

NOTE: Before installation, field finish wood with a minimum two coats for final protective finish.

- B. Glass and Glazing:
 - 1. Safety Glazing: In compliance with ANSI Z97.1 and CPSC 16CFR 1201.
 - a. Glass Acoustical Performance (ASTM E413 and ASTM E1332): STC.

NOTE: Unlike wet glazing, NanaWall's standard dry glazing method helps reduce instances of seal failure.

2. Manufacturer's [**tempered**] [**and**] [**laminated**] glass lites in [**single**] [**double**] insulated glazing units, dry glazed with glass stops on the inside.

NOTE: Select and edit glass type(s) to meet building code, wind-load design, acoustic, bullet resistant and/or security, and other project requirements with other glass available from manufacturer.

Custom layouts with horizontal mullions, simulated divided lites, inserts, and high bottom rails are possible.

Contact NanaWall for availability of other commercial glass types.

- a. Glass Lite / Insulated Glass Unit (IGU):
 - 1). Single: 1/4 inch (6 mm) thick.
 - 2). Double IGU: 15/16 inch (24 mm) thick.

NOTE: Subparagraphs below are options for single and double IGU items above.

- a). IGU Fill:
 - i. [Low-E]
 - ii. [Argon filled]
 - iii. [Air filled]
- b). Glass Spacers: Manufacturer's standard
 - i. [silver gray finish with capillary tubes]
 - ii. [black finish with capillary tubes]
 - iii. [silver gray finish without capillary tubes]
 - iv. [black finish without capillary tubes] .
- b. Glass Lite Type:
 - 1). Standard

NOTE: Items below are options and may require an upcharge.

- 2). [Low iron]
- 3). [Solar bronze]
- 4). [Solar gray]

C. Tilt Turn Hardware:

1. Manufacturer's standard cam type multipoint locking mechanism.
 - a. Concealed multipoint locking mechanism operated by a single locking handle.
2. Manufacturer's standard hinges, pins, strikes, and limit stays.
3. Lever Handle - Finish:
 - a. Brushed satin stainless steel
 - b. [Black titanium stainless steel]
4. Handle Height:
 - a. Centered.

NOTE: Centered above is standard with other options below. Edit to meet project requirements.

- b. [41-3/8 inch (105 cm) centered from bottom of panel.]
- c. [As indicated.]

- D. Rain Channel: [**Clear**] [**Dark bronze**] anodized extruded aluminum channel.
- E. Weatherstripping: Manufacturer's standard double layer EPDM.
- F. Fasteners: Stainless steel screws for connecting frame components.

2.04 FABRICATION

- A. Tilt Turn Wood Windows: Solid, three-layer, cross grained wood frame and sash profiles, tilt-turn hardware and handles, rain channel, glass and glazing and weatherstripping components needed to construct a Dual Action Tilt Turn window.
 - 1. Wood panel construction to include close tolerance mortise and tenon glued and pinned corners.
 - 2. Each unit factory pre-assembled and shipped with all components and installation instructions.
 - 3. Exposed work to be carefully matched to produce continuity of line and design with all joints.
 - 4. No raw edges visible at joints.
 - 5. Wood frame and panel components to be sealed with a clear sand sealer or primer plus one additional coat.

2.05 ACCESSORIES

- A. Fixed insect screening.
- B. Provide sidelights and transoms, as indicated.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examination and Acceptance of Conditions per Section 01 70 00 and as follows:
 - 1. Carefully examine rough openings with Installer present, for compliance with requirements affecting Work performance.
 - a. Verify that field measurements, substrates, tolerances, levelness, plumbness, cleanliness and other conditions are as required by the manufacturer, and ready to receive Work.
 - b. Verify the structural integrity of the header for deflection with live and dead loads limited to the lesser of L/720 of the span or 1/4 inch (6 mm). Provide structural support for lateral loads, and both wind load and eccentric load when the panels are stacked open.
 - 2. Proceed with installation only after unsatisfactory conditions have been corrected.

3.02 INSTALLATION

- A. General: Install Wood Window system in accordance with the Drawings, approved submittals, manufacturers' recommendations and installation instructions, and as follows:
 - 1. Properly flash, waterproof and seal around opening perimeter.
 - 2. Securely attach anchorage devices to rigidly fit frame in place, level, straight, plumb and square. Install frame in proper elevation, plane and location, and in proper alignment with other work
 - 3. Install sash, handles, screens and other accessories in accordance with manufacturer's recommendations and instructions.
 - 4. Finishing: Field finish wood under Section 09 9000; Seal and finish promptly after installation and prior to exposure to weather.

3.03 FIELD QUALITY CONTROL

- A. Field Tests and Inspections per Section 01 40 00 of the following:

1. Verify the Wood Window system operates and functions properly. Adjust hardware for proper operation.
 - B. Non-Conforming Work: Repair or replace non-conforming work as directed by the Architect; see General and Supplementary Conditions, and Division 01, General Requirements.
- 3.04 CLEANING AND PROTECTION
- A. Keep units closed and protect Wood Window installation against damage from construction activities.
 - B. Remove protective coatings and use manufacturer recommended methods to clean exposed surfaces.

END OF SECTION

DISCLAIMER:

Nana Wall Systems, Inc. takes no responsibility for product selection or application, including, but not limited to, compliance with building codes, safety codes, laws, or fitness for a particular purpose. This guide specification is not intended to be verbatim as a project specification without appropriate modifications for the specific use intended and the requirements of a specific construction project.

www.nanawall.com